

Edition 1.0 2013-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE



High-voltage switchgear and controlgear – Part 4: Handling procedures for sulphur hexafluoride (SF₆) and its mixtures

Appareillage à haute tension – Partie 4: Utilisation et manipulation de l'hexafluorure de soufre (SF_6) et des mélanges contenant du SF_6





THIS PUBLICATION IS COPYRIGHT PROTECTED Copyright © 2013 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office Tel.: +41 22 919 02 11 3, rue de Varembé Fax: +41 22 919 03 00

CH-1211 Geneva 20 info@iec.ch Switzerland www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



Edition 1.0 2013-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE



High-voltage switchgear and controlgear – Part 4: Handling procedures for sulphur hexafluoride (SF₆) and its mixtures

Appareillage à haute tension –

Partie 4: Utilisation et manipulation de l'hexafluorure de soufre (SF_6) et des mélanges contenant du SF_6

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

PRICE CODE CODE PRIX

ICS 29.130.10; 29.130.99 ISBN 978-2-8322-1042-0

Warning! Make sure that you obtained this publication from an authorized distributor.

Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

		ORD			
	RODUCTION				
1		eral			
	1.1	Scope			
2	1.2	Normative referencess and definitions			
3	•	handling during installation and commissioning			
	3.1 3.2	General Evacuation, filling and checking the SF ₆ quality after filling			
	3.3	Topping-up of SF ₆ pre-filled compartments to the rated filling	1 1		
	0.0	pressure/density	13		
	3.4	Filling sealed pressure systems	15		
4	SF ₆ handling during normal service life				
	4.1	Re-filling of SF ₆ to the rated filling pressure/density	15		
	4.2	Checking the SF ₆ quality	16		
		4.2.1 General			
		4.2.2 Measurement of the SF ₆ quality with portable equipment			
_		4.2.3 Sampling and shipment of SF ₆ for off-site analysis			
5	SF ₆ recovery and reclaim during maintenance				
	5.1	General	18		
	5.2	SF ₆ recovery and reclaim from any compartment of controlled or closed pressure systems containing non-arced or normally arced SF ₆	18		
	5.3	Recovery and reclaim from any compartment of controlled or closed	10		
	0.0	pressure systems containing heavily arced SF ₆	20		
6	Dismantling of SF ₆ electric power equipment at the end-of-life				
	6.1	General	22		
	6.2	End-of-life of controlled or closed pressure systems			
	6.3	End-of-life of sealed pressure systems			
	6.4	SF ₆ recovery and reclaim at the end-of-life of sealed pressure systems			
	6.5	Dismantling of electric power equipment at the end-of-life			
	6.6	By-products at the end-of-life			
		(informative) Storage and transportation of SF ₆			
		(informative) Safety and first aid			
		(informative) Training and certification			
An	nex D	(informative) Description of SF ₆ Handling Equipment	43		
An	nex E	(informative) Sulphur hexafluoride	51		
An	nex F	(informative) Environmental effects of SF ₆	55		
An	nex G	(informative) SF ₆ by-products	58		
An	nex H produ	(informative) Procedure for evaluating the potential effects on health of SF ₆ cts	61		
An	nex I ((informative) Cryogenic reclaim of SF ₆	67		
		(normative) Handling of SF ₆ mixtures			
		phy			
	0	· ·			
Fia	ura 1	- Evacuation, filling and checking the SEc quality after filling	12		

Figure 2 – Topping-up of SF ₆ pre-filled compartments to the rated filling pressure/density	14
Figure 3 – SF ₆ re-filling to the rated filling pressure/density	
Figure 4 – Checking the SF ₆ quality on-site	
Figure 5 – SF ₆ sampling and shipment	
Figure 6 – Example of recovery and reclaim from any compartment of controlled or closed pressure systems containing non-arced or normally arced SF ₆	
Figure 7 – Example of recovery and reclaim from any compartment of controlled or closed pressure systems containing heavily arced SF ₆	21
Figure 8 – End-of-life of controlled or closed pressure systems	23
Figure 9 – End-of-life of sealed pressure systems	24
Figure 10 – SF ₆ recovery and reclaim at the end-of-life of sealed pressure systems	25
Figure 11 – Dismantling of electric power equipment	27
Figure D.1 – General purpose reclaimer	43
Figure D.2 – Gas mixing device	49
Figure E.1 – Pressure/temperature/density characteristics for SF ₆ [16]	52
Figure H.1 – Procedure for the evaluation of the potential effects on health due to arcing	65
Figure H.2 – Procedure for the evaluation of the potential effects on health due to low energy discharges	66
Figure I.1 – Saturated vapour pressure of various gases as a function of temperature	68
Figure I.2 – Typical cryogenic reclaimer for SF ₆ recovery on site	69
Figure I.3 – Typical cryogenic reclaimer for removing contaminants	70
Figure J.1 – Vapour pressure of SF ₆	74
Figure J.2 – Maximum SF ₆ storage density to avoid SF ₆ liquefaction	75
Table 1 – Evacuation, filling and checking the SF ₆ quality after filling	13
Table 2 – Topping-up of SF ₆ pre-filled compartments to the rated filling pressure/density	14
Table 3 – SF ₆ re-filling to the rated filling pressure/density	16
Table 4 – Checking the SF ₆ quality on-site	17
Table 5 – SF ₆ sampling and shipment	18
Table 6 – Example of recovery and reclaim from any compartment of controlled or closed pressure systems containing non-arced or normally arced SF6	20
Table 7 – Example of recovery and reclaim from any compartment of controlled or closed pressure systems containing heavily arced SF ₆	22
Table 8 – SF ₆ recovery at the end-of-life of sealed pressure systems	26
Table 9 – Expected SF ₆ characteristics and quantity of by-products	28
Table A.1 – Methods for storage of SF ₆	29
Table A.2 – Container types and labelling required for storage and transportation of SF6	30
Table A.3 – International regulations for shipment of SF ₆	31
Table B.1 – Measures when working with SF ₆ electric power equipment	33
Table B.2 – Safety measures when opening or accessing gas compartments	34
Table B.3 – Neutralising solutions	35
Table B.4 – Additional safety measures	37

Table D.1 – Typical filter types used during SF ₆ reclaim	44
Table D.2 – Gas measuring devices	47
Table E.1 – Main chemical characteristics of SF ₆ [16]	51
Table E.2 – Main physical characteristics of SF ₆ [16]	53
Table E.3 – Main electrical characteristics of SF ₆ [16]	53
Table H.1 – OELs for SO ₂ , HF, and S ₂ F ₁₀	63
Table H.2 – SOF ₂ production rate	63

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR -

Part 4: Handling procedures for sulphur hexafluoride (SF₆) and its mixtures

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-4 has been prepared by subcommittee 17A: High-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

This first edition cancels and replaces the first edition of IEC/TR 62271-303 published in 2008.

This first edition constitutes a technical revision. This edition includes the following significant technical changes with respect to the previous edition:

- a) the description of the potential effects on health of SF_6 by-products (former Annex D of IEC/TR 62271-303:2008) has been replaced by the calculation methods for evaluating of the potential effects on health of SF_6 by-products (see Annex H);
- b) information about cryogenic reclaim of SF₆.have been added (see Annex I);
- c) handling procedures for the most popular SF₆ mixtures have been added (see Annex J).

The text of this standard is based on the following documents:

FDIS	Report on voting
17A/1044/FDIS	17A/1051/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62271, published under the general title *High-voltage switchgear* and controlgear, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- · replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

As agreed with TC 10, annexes A, E, F, G, H and I will be removed from this document as soon as the revised editions of IEC 60376 and IEC 60480 have been published.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR -

Part 4: Handling procedures for sulphur hexafluoride (SF₆) and its mixtures

1 General

1.1 Scope

This part of IEC 62271 applies to the procedures for handling of SF_6 during installation, commissioning, normal and abnormal operations, disposal at the end-of-life of high-voltage switchgear and controlgear.

These procedures are regarded as minimum requirements to ensure the safety of personnel working with SF_6 (see Annex B) and to minimize the SF_6 emission to the environment.

This standard generally applies also to gas mixtures containing SF₆. The particularities for their handling are covered in Annex J.

NOTE 1 Throughout this standard, use of the term High-Voltage (refer to IEC 60050-601:1985, 601-01-27) means a rated voltage above 1 000 V. However the term Medium Voltage (refer to IEC 60050-601: 1985, 601-01-28) is commonly used for distribution systems with voltages above 1 kV and generally applied up to and including 52 kV.

NOTE 2 Throughout this standard, the term "electric power equipment" stands for "high-voltage and medium-voltage switchgear and controlgear".

NOTE 3 Throughout this standard, the term "pressure" stands for "absolute pressure".

1.2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-441, International Electrotechnical Vocabulary – Chapter 441: Switchgear, controlgear and fuses

IEC 60050-601, International Electrotechnical Vocabulary – Chapter 601: Generation, transmission and distribution of electricity – General

IEC 60376, Specification of technical grade sulphur hexafluoride (SF $_6$) for use in electrical equipment

IEC 60480, Guidelines for the checking and treatment of sulphur hexafluoride (SF_6) taken from electrical equipment and specifications for its re-use

IEC 62271-1, High-voltage switchgear and controlgear - Part 1: Common specifications

EN 1089-3, Transportable gas cylinders. Gas cylinder identification (excluding LPG). Colour coding