UL 347

STANDARD FOR SAFETY

Medium-Voltage AC Contactors, Controllers, and Control Centers

UL Standard for Safety for Medium-Voltage AC Contactors, Controllers, and Control Centers, UL 347

Seventh Edition, Dated November 23, 2020

Summary of Topics

The Seventh Edition of the Standard for Medium-Voltage AC Contactors, Controllers, and Control Centers, UL 347 has been issued to reflect the latest ANSI approval date, and to incorporate the proposals dated November 1, 2019 and May 29, 2020.

The requirements are substantially in accordance with Proposal(s) on this subject dated November 1, 2019 and May 29, 2020.

No Text on This Page

Association of Standardization and Certification
NMX-J-564/106-ANCE
Third Edition

CSA Group
CSA C22.2 No. 253:20
Third Edition

Underwriters Laboratories Inc.
UL 347
Seventh Edition

Medium-Voltage AC Contactors, Controllers, and Control Centers

November 23, 2020

ANSI/UL 347-2020

Commitment for Amendments

This standard is issued jointly by the Association of Standardization and Certification (ANCE), the Canadian Standards Association (operating as “CSA Group”), and Underwriters Laboratories Inc. (UL). Comments or proposals for revisions on any part of the standard may be submitted to ANCE, CSA Group, or UL at anytime. Revisions to this standard will be made only after processing according to the standards development procedures of ANCE, CSA Group, and UL. CSA Group and UL will issue revisions to this standard by means of a new edition or revised or additional pages bearing their date of issue. ANCE will incorporate the same revisions into a new edition of the standard bearing the same date of issue as the CSA Group and UL pages.

ISBN 978-1-4883-2407-9 © 2020 Canadian Standards Association

This Standard is subject to review within five years from the date of publication, and suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup. org and include "Proposal for change" in the subject line: Standard designation (number); relevant clause, table, and/or figure number; wording of the proposed change; and rationale for the change.

To purchase CSA Group Standards and related publications, visit CSA Group’s Online Store at store.csagroup.org or call toll-free 1-800-463-6727 or 416-747-4044.

This ANSI/UL Standard for Safety consists of the Seventh Edition.

The most recent designation of ANSI/UL 347 as an American National Standard (ANSI) occurred on November 23, 2020. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page (front and back), or the Preface.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at https://csds.ul.com.

To purchase UL Standards, visit UL's Standards Sales Site at http://www. shopulstandards. com/HowToOrder.aspx or call toll-free 1-888-853-3503.

CONTENTS

Preface **7**

1 General 9
1.1 Scope and object 9
1.2 Normative references, component standards, and general requirements 9
2 Normal and Special Service Conditions 10
2.1 Normal service conditions 10
2.2 Special service conditions 10
3 Definitions 11
3.1 General terms 11
3.2 Assemblies of controlgear 13
3.3 Parts of assemblies 13
3.4 Switching devices 13
3.5 Parts of a controller 15
3.6 Operation 16
3.7 Characteristic quantities 17
3.101 Fuses 20
3.201 Medium-voltage fuse 21
3.202 Index of definitions 21
4 Controller and Control Center Ratings and Characteristics 25
4.1 Rated maximum voltage (U_r) 25
4.2 Rated insulation level (U_d), (U_p) 25
4.3 Rated frequency (f_r) 26
4.4 Rated continuous current and temperature rise 26
4.5 Rated short-time withstand current (I_k) 26
4.6 Rated peak and momentary withstand current 27
4.7 Rated duration of short-circuit (t_k) 27
4.8 Rated supply voltage of operating devices and of auxiliary and control circuits (U_a) 28
4.9 Rated supply frequency of closing and opening devices and of control circuits 28
4.10 Rated pressure of compressed gas supply for installation and/or operation 28
4.101 Rated operational current or rated operational power (I_e) 28
4.102 Rated duties 28
4.103 Rated making and breaking capacities 28
4.104 Utilization category 28
4.105 Mechanical endurance (standard and optional) 29
4.106 Electrical endurance 29
4.107 Coordination with medium-voltage fuses 29
4.108 Types and characteristics of automatic change-over devices and automatic acceleration control devices 29
4.109 Types and characteristics of autotransformers or reactors 29
4.110 Types and characteristics of the starting resistors for rheostatic motor starters 30
4.111 Characteristics dependent on starter type 30
4.112 Rated capacitive switching currents 30
4.201 Characteristics of Class E2 controllers 31
4.202 Fault-interrupting rating 31
4.203 Control center short-circuit rating 31
4.204 Starting duty of reduced-voltage starters 32
4.205 Duty rating for solid state resistive load controllers 33
5 Design and Construction 33
5.1 Requirements for liquids 33
5.2 Requirements for gases 33
5.3 Provisions for protective grounding 33
5.4 Auxiliary and control equipment 35

5.5 Dependent power operation 35
5.6 Stored energy operation 35
5.7 Independent manual operation 35
5.8 Operation of releases 35
5.9 Low- and high-pressure interlocking and monitoring devices 35
5.10 Markings 35
5.11 Interlocks 41
5.12 Position indication 42
5.13 Degrees of protection (optional) 43
5.14 Spacings 43
5.15 Gas and vacuum tightness 44
5.16 Liquid tightness 44
5.17 Flammability 44
5.18 Electromagnetic compatibility 44
5.19 X-ray emission 45
5.101 Types of relay or release 45
5.102 Enclosures 45
5.201 Latched controllers 48
5.202 Power circuit isolating means 48
5.203 Equipment protection 50
5.204 Service equipment 51
5.205 Internal wiring 55
5.206 Terminals and connections 57
5.207 Bus bar connections 58
5.208 Connector and grounding kits 58
5.209 Insulating material 58
5.210 Wire-bending space for field-installed conductors 58
5.211 Field-installed accessories (kits) 59
5.212 Blank spaces, provision for future controllers, and spare controllers 59
5.213 Insulated bus (optional) 60
5.214 Controllers – general requirements 60
6 Type Tests 60
6.1 General 60
6.2 Dielectric tests 61
6.3 Radio interference voltage (RIV) test 64
6.4 Resistance measurement 65
6.5 Temperature-rise tests 66
6.6 Short-time, momentary, and peak withstand current bus tests 71
6.101 Mechanical tests 73
6.102 Make and break capacity 74
6.103 Overload test 76
6.104 Fault interruption test 78
6.105 Verification of operating limits and characteristics of overload relays 82
6.106 Verification of coordination with SCPDs 83
6.107 Electrical endurance tests 83
6.108 Motor switching tests 83
6.109 Capacitive current switching tests 83
6.201 Switching capacity test – isolating means 85
6.202 Short-time capability 86
6.203 Driven rain test 88
6.204 Mechanical tests of viewing panes 89
6.205 Enclosure ground integrity test 89
6.206 Shutter integrity test 89
6.207 Rod entry test 89
6.208 Operation tests for all solid state controllers 90
7 Routine Tests 91

7.1 Power-frequency voltage withstand test on the main circuit 91
7.2 Power-frequency voltage withstand test on auxiliary and control circuits 92
7.3 Measurement of the resistance of the main circuit 92
7.4 Tightness test (vacuum integrity test) 92
7.5 Design and visual checks 92
7.101 Operating tests 92
7.102 Tests dependent on controller type 93
7.201 Routine tests – general 93
TABLES 94
FIGURES 103

Annex A (Normative) – References

Annex B – (Reserved)

Annex C (Informative) – Markings required to be translated and suggested French and Spanish translations

Annex D (Informative) – Standards for components

Annex E (Normative) – Voltage Dividers Used in Medium Voltage Controllers

E1 Scope 119
E2 Definitions 119
E3 Construction 119
E4 Performance 120
E4.2 Dielectric withstand test 120

No Text on This Page